


- Rated frequency: 50~60Hz
- Rated current of the base: 100A
- Rated current of the fuse-holder: 100A
- Dry power frequency withstand voltage 50Hz 1min (to earth and between poles / across the isolating distance): 85kV
- 1.2/50µs lightning impulse withstand voltage (to earth and between poles / across the isolating distance): 185KV
- Rated symmetrical interrupting current; 8kA
- Rated asymmetrical interrupting current: 12kA
- Material of the fuse holder: Fiber glass
- Material of the base insulator: Porcelain

**Creepage distance: 720mm**

	Name	signature	Date		<b>ERKAN ELEKTROMEKANİK MALZEMELER ELEKTRİK MÜHENDİSLİK TAAHİTH.İHR.SAN. ve TİC. AŞ. (POLIPAR BRAND OWNER)</b>	
Designer	Aykut ARSLAN		30.08.2018			
Examiner	ALPARSLAN DAGIÇLEN					
Collator						
Assessor						
Technology				Cut Out	36 kV Porcelain Cut Out	
Marks item checked date no signature changed date				serial no 2018 -11361001	scale: 3/5	assembly drawing no

A4