

POLIPAR		Test Report	FUSE CUT-OUT
Contents			
Number	Contents		Pages
1	Cover		
2	Contents		1
3	General		2
4	Photos of the samples		3
5	Test conclusion		4
6	Lightning impulse voltage tests		5
7	Power-frequency voltage dry tests		6
8	Power-frequency voltage wet tests		7
9	Temperature-rise test		8
10	Diagram of measuring points of temperature-rise		9
11	Mechanical test		10
12	Operating time-current characteristics test		11~12
13	Pre-arcing time-current characteristics test		13~14
14	Breaking test		15~20
15	Assembly		22
16	Schematic diagram of power-frequency withstand voltage test		23
17	Schematic diagram of lightning impulse withstand voltage test		24
18	Schematic diagram of breaking test		25~26
19	Oscillogram of lightning impulse withstand voltage test		27
20	Oscillogram of operating time-current characteristics test		28~33
21	The prospective oscillogram of breaking test		34~38
22	TRV of breaking test		39~42
23	Oscillogram of breaking test		43~60
24	Mechanical test		61
25	Thermal cycle and torque tests		62
26	Torque tests		63
27	Radio interference voltage (r.i.v.) tests		64
28	Dimensional and Galvanising Test		65
29	Measurement of Resistance of fuse-links is for resistance test		66
	Blank below		

POLIPAR		Test Report	FUSE CUT-OUT		
General					
Test category	Type test				
Type and name of the samples	Fuse cutouts				
Manufacturer	Erkan Elektromekanik A.Ş (Polipar Brand Owner)				
Address	1203. Street No: 38/L-5/D Ostim Organized Industrial Area, Ankara/Türkiye, Postcode: 06374				
Manufacturing date	2021-12				
Main technical parameters of the samples	Rated voltage (kV)	38			
	Rated current (A)	100			
	Rated frequency (Hz)	50			
	Rated current of the fuse-base (A)	300			
	Rated current of the equipped fuse-link (A)	6、 100			
	Rated breaking current (kA)	5			
	Power-frequency withstand voltage dry test (phase to earth) (kV)	70			
	Power-frequency withstand voltage dry test (distance) (kV)	80			
	Power-frequency withstand voltage wet test (phase to earth) (kV)	70			
	Power-frequency withstand voltage wet test (distance) (kV)	80			
	Lightning impulse withstand voltage dry test (phase to earth) (kV) Peak	170			
	Lightning impulse withstand voltage dry test (distance) (kV) Peak	195			
Description	36kV Porcelain Fuse Cutout				
Test period: From June. 3, 2022 to June. 15, 2022					

POLIPAR

Test Report

FUSE CUT-OUT

Photos of the samples

POLIPAR	Test Report	FUSE CUT-OUT	
Test conclusion			
Manufacturer	Erkan Elektromekanik A.Ş (Polipar Brand Owner)		
Type of the samples	FUSE CUT-OUT		
Name of the samples	Fuse cutouts		
Manufacturer	Erkan Elektromekanik A.Ş (Polipar Brand Owner)		
Test items and results	Power-frequency voltage dry tests [phase to earth: 35kV 1min; fracture: 39kV 1min]	PASS	
	Power-frequency voltage wet tests [phase to earth: 30kV 1min]	PASS	
	Lightning impulse voltage dry tests [phase to earth: 95kVPeak; fracture: 105kVPeak]	PASS	
	Temperature-rise test[100A]	PASS	
	Breaking tests1[15.5kV, 8kA, 6A and 100A 3 times each]	PASS	
	Breaking tests2[15.5kV, 4.8~6.4kA, 6A and 100A 3 times each]	PASS	
	Breaking tests3[15.5kV, 1.6~2.4kA, 6A and 100A 1 time each]	PASS	
	Breaking tests4[15.5kV, 400~500A, 6A 2 times each]	PASS	
	Breaking tests5[15.5kV, 162~198A, 6A 2 times each]	PASS	
	Pre-arc time-current characteristics test	PASS	
	Operating time-current characteristics test	PASS	
	Mechanical tests: Mechanical testing of fuse bases and fuse-carrying parts [500times"CO"]	PASS	
	Thermal Cycle test	PASS	
	Torque test	PASS	
	Dimensional and Galvanising test	PASS	
	Radio interference voltage (r.i.v.) tests	PASS	
	Measurement of Resistance of fuse-links	PASS	
Test standards	IEEEStdC 37.41 IEEE Standard Design Tests for High-Voltage(>1000V)Fuses and Accessories		
	IEEE Std C 37.42 IEEE Standard Specifications for High-Voltage (> 1000V)Fuses and Accessories		
Test conclusion	The tests have been carried out from 6/3-6/15/2022. the test items meet the relevant clauses of above test standards and technical specifications, and the samples have passed the tests.		
Compiled by:	Proofread by:	Checked by:	Approved by:
Date:	Date:	Date:	Date:

POLIPAR		Test Report			FUSE CUT-OUT								
Dielectric test (lightning impulse withstand voltage dry test)													
Test date: June.3, 2022													
Status of samples or test parts	Voltage applied to	Earth connected to	Positive polarity			Negative polarity							
			Voltage (kV)	Applied times	Puncture times	Voltage (kV)	Applied times						
Fuse distance in closed condition	Aa	F	169.9	15	0	169.9	15						
Fuse distance in open condition	A	a	194.9	15	0	194.9	15						
	a	A	194.9	15	0	194.9	15						
<p>Status of the sample before the test: new.</p> <p>Note: A——one side terminal of tested parts; a——the other side terminal of tested parts;</p> <p>F——metal parts and install base of the sample</p> <p>The data in the table has been corrected into the standard atmospheric condition.</p>													
Atmospheric conditions of test zone	P=101.6kPa; Environmental temperature t=26°C;			Relative humidity: 65% Atmospheric correction factor Kt=0.9993 Altitude correction factor Ka= /									

POLIPAR	Test Report			FUSE CUT-OUT						
Dielectric test (power-frequency withstand voltage dry test)										
Test date: June.3, 2022										
Status of samples or test parts	Voltage applied to	Earth connected to	1min power-frequency withstand voltage (dry condition)							
			Voltage (kV)	Applied times	Puncture times					
Fuse distance in closed condition	Aa	F	69.6	1	0					
Fuse distance in open condition	A	a	79.6	1	0					
	a	A	79.6	1	0					
Status of the sample before the test: new.										
Note: A—one side terminal of tested parts; a—the other side terminal of tested parts;										
F—metal parts and install base of the sample										
The data in the table has been corrected into the standard atmospheric condition.										
Atmospheric conditions of test zone	P=101.6kPa; Environmental temperature t=26°C; Relative humidity: 65% Atmospheric correction factor Kt=0.9948 Altitude correction factor Ka= /									

POLIPAR	Test Report			FUSE CUT-OUT						
Dielectric test (power-frequency withstand voltage wet test)										
Test date: June 5, 2022										
Average rate of sprinkling	Horizontal component:1.4mm/min Vertical component:1.3mm/min		Conductive rate: 107μs/cm		Water temperature: 13.1°C					
Status of samples or test parts		Voltage applied to	Earth connected to	1min power-frequency withstand voltage (wet condition)						
Fuse distance in closed condition		Aa	F	Voltage (kV)	Applied times					
Fuse distance in open condition		A	a	81.7	1					
		a	A	81.7	1					
Atmospheric conditions of test zone	P=102.5kPa; Environmental temperature t=26.; Relative humidity: 65%			Atmospheric correction factor Kt=1.0209 Altitude correction factor Ka= /						

Status of the sample before the test: no maintainance.

Note: A——one side terminal of tested parts; a——the other side terminal of tested parts;

F——metal parts and install base of the sample


The data in the table has been corrected into the standard atmospheric condition.

POLIPAR	Test Report		FUSE CUT-OUT		
Temperature-rise test					
Test date: June.6, 2022					
Test current (A)	100	Test pole: single pole	Current frequency: 50Hz		
Contact pressure (N)	A: / B: / C: /		Ambient wind speed: 0.05m/s		
Connect busbar	Copper bar Dimension: 160 mm ² Length: the head and tail end are 1.0m respectively				
Measuring data of temperature-rise (K)					
Number or name of measuring parts	Temperature-rise (ambient temperature 20°C)	Permitted temperature-rise value (K)	Remark		
1	46	/	Reference point		
2	49	65			
3	60	75			
4	52	65			
5	54	65			
6	67	/			
7	55	65			
8	51	65			
9	48	/	Reference point		
Note: for the numbers of measuring parts and the measuring parts of thermocouple, see sketch map.					

POLIPAR

Test Report

FUSE CUT-OUT


Diagram of measuring points of temperature-rise

POLIPAR	Test Report	FUSE CUT-OUT
Mechanical test		
Test date: June. 06, 2022		
<p>1. Mechanical strength of fuse-base and fuse-carrier 200 times of closing and 200 times of opening are made respectively on three fuses At the conclusion of the operations, the fuses shall be in an operable condition with no failure in the insulators and mechanical performance.</p>		
Test date: June 06, 2022		
<p>2. Mechanical strength of fuse-links a) Static test: The specified axial tensile forces of 60 N are applied on one fuse-link gradually, with no precipitous action. No any damage is observed on the fuse-link after 30min. (such as rupture, loosening, slipping of connections, or elongation of components) b) Dynamic test: The fuse-links are installed on the fuse according to normal service condition and 20 times of closing and 20 times of opening are made respectively. After the operations, no any damage is observed on the fuse by visual inspection. (such as rupture, elongation of components, loosening or slipping of connections)</p>		
<p>Note: The test Passed.</p>		

POLIPAR		Test Report		FUSE CUT-OUT					
Operating time-current characteristics test									
Test date: June 6, 2022									
Ambient temperature: 15.9°C									
Connect lead length	Length: 1.2m								
Test current (A)	Rated current of the fuse (A)	Measured melting time (ms)	Test times	Connect lead dimension (mm ²)	Oscillogram №				
207.6	100	9030	1	160	001				
260.3	100	3220	1	160	002				
1559	100	120.9	1	160	003				
12.3	6	2890	1	160	004				
13.8	6	1320	1	160	005				
73.0	6	128.6	1	160	006				
Status of the sample before the test: no maintenance.									
Note: the test is carried out at 36kV.									

Operating time-current characteristics curves


No: /



POLIPAR		Test Report		FUSE CUT-OUT		
Pre-arcing time-current characteristics test						
Test date: June.5, 2022						
Ambient temperature: 15.8°C						
Connect lead length	Length: 2.0m					
Test current (A)	Rated current of the fuse (A)	Measured melting time (s)	Test times	Connect lead dimension (mm ²)		
202	100	9.0	1	160		
259	100	3.1	1	160		
1542	100	0.12	1	160		
12.4	6	2.7	1	160		
13.8	6	1.3	1	160		
73.3	6	0.11	1	160		
Status of the sample before the test: no maintainance.						
Note:						

Pre-arcing time-current characteristics curves

No: /



POLIPAR			Test Report		FUSE CUT-OUT			
			Breaking test					
			Test contents, methods, circuit, conditions and prospective values					
Test items	Test operating sequence or test parts	Test times	Test phases/methods	Test circuit	Test line voltage (kV)	Breaking current I_k (kA)		
Test duty 1	O	3 times of 100A and 6A respectively	Direct test	/-3	36	5		
Test duty 2	O	3 times of 100A and 6A respectively	Direct test	/-3	36	3~4		
Test duty 3	O	1 time of 100A and 6A respectively	Direct test	/-3	36	1.0~1.5		
Test duty 4	O	6A 2 times	Direct test	/-3	36	0.4~0.5		
Test duty 5	O	6A 2 times	Direct test	/-4	36	0.0162 ~-0.0198		


*: the closing phase angles of three times test on duty 1 and duty 2: $5^\circ \sim 15^\circ$ (the first time), $85^\circ \sim 105^\circ$ (the second time), $130^\circ \sim 150^\circ$ (the third time).

POLIPAR		Test Report		FUSE CUT-OUT					
Breaking test duty 2									
Test date: June. 10, 2022									
Source side cosφ: <0.15									
Test duty	Oscillogram №	Test voltage (kV)	(prospective) Breaking current (kA)	Rated current of the fuse (A)	Cut-off current (kA)				
Metallic short-circuit	/Y002	36.4	3.5						
Circuit adjustment	/-TRV002								
2	/-T007	36.4	(3.5)	6	6.4				
2	/-T008	36.4	(3.5)	100	7.2				
2	/-T009	36.4	(3.5)	6	3.9				
2	/-T010	36.4	(3.5)	100	5.7				
2	/-T011	36.4	(3.5)	6	1.8				
2	/-T012	36.4	(3.5)	100	6.7				
Prospective TRV: U _c (kV)=66.2 t ₃ (μs)=281									
Power-frequency voltage (kV)		Duration (ms)	Power-frequency recovery voltage (kV)	Power factor of circuit	Closing angle after voltage exceed zero (°)				
t ₃ (μs)				U _c (kV)	TRV				
Checking circuit				t ₃ (μs)	Status of the sample				
66.9 281									
Status of the sample before the test: /									

POLIPAR		Test Report		FUSE CUT-OUT					
Breaking test duty 3									
Test date: June. 10, 2022									
Test duty	Oscillogram №	Test voltage (kV)	(prospective) Breaking current (kA)	Rated current of the fuse (A)	Cut-off current (kA)				
Metallic short-circuit	/Y003	36.4	1.2						
Circuit adjustment	/TRV003								
3	/T013	36.4 (1.2)	6	1.4	9.0				
3	/T014	36.4 (1.2)	100	1.8	20.1				
Status of the sample before the test: /									

Assembly

No:



Min Creepage Distance:60mm

35.36
34.33/32.31
33.21/28.22
29.23/24.22
31.21

Sr	Description	Qty	Material	(kg)
33	6255.6-3 lower connector	1	bronze	
32	6255.6-2 lower connector plate	1	bronze	
31	6255.6-1 lower connector base	1	SS	
30	fuse link	1		
29	GB/T 867-1986 pin 3X9	4	bronze	
28	6251.6-3 auxiliary contact	2	SS	
27	6251.6-2 conduct contact	2	bronze	
26	6251.6-1 Hinge	1	brass	
25	6266.5.1-4 nut	1	bronze	
24	GB/T 867-1986 rivet pin 5X82	1	SS	
23	6255.3-3 tweak spring	1	SS	
22	6251.5-1A latch spring	1	SS	
21	6251.5-1-B trunion	1	brass	
20	6251.5-2A pull ring	1	brass	
19	6270.5.5 tube holder	1	brass	
18	GB/T 19.1-2000B column pin 4X26	3	SS	
17	6262.2-1C fuse tube	1	Fiber glass	
16	6270.1.1 hook	1	Galv/steel	
15	6251.5-1A upper cap	1	bronze	
14	6270.3.3 Spring	1	SS	
13	6270.3.4 upper contact plate	1	bronze	
12	6270.3.2 upper contact	1	Galv/steel	
11	GB/T 6170-2000 nut M10	4	SS	
10	GB/T 93-1987 spring washer 10	4	SS	
9	GB/T 95-2002 flat washer 10	4	SS	
8	GB/T 12-1988 bolt M10X25	1	SS	
7	GB/T 12-1988 bolt M10X40	1	SS	
6	6251.2-2B lower connector	1	bronze	
5	6251.2.1A upper connector	1	bronze	
4	GB/T 12-1988 bolt M10X50	1	SS	
3	6255.1.3 fittings	1	Galv/steel	
2	6255.1.2 Mounting pin	1	Galv/steel	
1	6251.1.1 insulator	1	Porcelain	


Outline drawing

POLIPAR
6kV PORCELAIN CUTOUT
100A

Date 2011/7/26

Schematic diagram of power-frequency
withstand voltage test

No: /-1




In the diagram:

AT: Booster CT: Current transform TT: Power-frequency test transform RP: Protected resistance
TO: Test object V1: Voltmeter A: Ammeter C1: HV arm capacitance of voltage divider
C2: LV arm capacitance of voltage divider V2: Peak voltmeter

Schematic diagram of lightning
impulse withstand voltage test

No: /-2



In the diagram:

C: Main capacitance of the impulse emitter RP: Parallel connected resistance of emitter(resistance on end of wave)

R_{se}: Arallel connected resistance of emitter (resistance before wave) C1: Load capacitance of emitter


C₁: HV arm capacitance of potentiometer

TO: Test object VM: Peak value of voltage meter

OSC: Oscillograph

Schematic diagram of breaking test
(test duty 1~4)


No: /-3



- | | | |
|---|---------------------------------------|--|
| CF——短路发电机 (short-circuit generator) | BD——保护断路器 (master circuit-breaker) | HK——合闸开关 (making switch) |
| CD——操作断路器 (operation circuit-breaker) | Rt1——功率因数调节电阻 (power factor resistor) | Lt1——调节电抗器 (adjustable reactor) |
| DB——短路变压器 (booster short-circuit transformer) | YH——电压互感器 (voltage transformer) | LH——电流互感器 (current transformer) |
| YH——分压器 (divider) | Rt2——功率因数调节电阻 (power factor resistor) | Lt2——调节电抗器 (adjustable reactor) |
| Rjld——接地电阻 (earthing resistor) | SP——试品 (test object) | TRV——暂态恢复电压 (transient recovery voltage) |
| CD1——操作断路器 (operation circuit-breaker) | HK1——合闸开关 (making switch) | |

Schematic diagram of breaking test
(test duty 5)

No: /-4





- CF——短路发电机 (short-circuit generator) BD——保护继电器 (protection relay)
- Rt1——功率因数调节电阻 (power factor resistor) Lt1——功率因数调节器 (power factor divisor)
- FY——分压器 (divider) Lt2——调节器 (regulator)
- Rt2——功率因数调节电阻 (power factor resistor) LH——电感线圈 (current coil)
- SP——试品 (test object) R——电阻器 (resistor)

Oscillogram of lightning impulse
withstand voltage test


No: /

/




Oscillogram of operating time-current
characteristics test

No: /-001




Oscillogram of operating time-current
characteristics test

No: /-002




Oscillogram of operating time-current
characteristics test

No: /-003




Oscillogram of operating time-current
characteristics test

No: /-004




Oscillogram of operating time-current
characteristics test

No: /-005




Oscillogram of operating time-current
characteristics test

No: /-006




The prospective oscillogram of breaking
test duty 1

No: /-Y001




The prospective oscillogram of breaking
test duty 2

No: /-Y002




The prospective oscillogram of breaking
test duty 3

No: /-Y003




The prospective oscillogram of breaking
test duty 4

No: /-Y004




The prospective oscillogram of breaking
test duty 5

No: /-Y005




TRV of breaking test duty 1

No: /-TRV001, TRV001-1




TRV of breaking test duty 2	
	No: /-TRV002,TRV002-1




TRV of breaking test duty 3

No: /-TRV003,TRV003-1




TRV of breaking test duty 4

No: /-TRV004,TRV004-1




Oscillogram of breaking test duty 1

No: /-T001




Oscillogram of breaking test duty 1

No: /-T002




Oscillogram of breaking test duty 1

No: /-T003




Oscillogram of breaking test duty 1

No: /-T004




Oscillogram of breaking test duty 1

No: /-T005




Oscillogram of breaking test duty 1

No: /-T006




Oscillogram of breaking test duty 2

No: /-T007




Oscillogram of breaking test duty 2

No: /-T008




Oscillogram of breaking test duty 2

No: /-T009




Oscillogram of breaking test duty 2

No: /-T010




Oscillogram of breaking test duty 2

No: /-T011




Oscillogram of breaking test duty 2

No: /-T012




Oscillogram of breaking test duty 3

No: /-T013




Oscillogram of breaking test duty 3

No: /-T014




Oscillogram of breaking test duty 4

No: /-T015




Oscillogram of breaking test duty 4

No: /-T016




Oscillogram of breaking test duty 5

No: /-T017



Oscillogram of breaking test duty 5

No: /-T018



POLIPAR	Test Report	FUSE CUT-OUT
Mechanical tests		
Test date: June.12, 2022		
1. Mechanical testing of fuse bases and fuse-carrying parts		
<p>The three fuses are closed and opened 500 times each.</p> <p>At the end of the operation, the fuse was in an operable condition without any damage to the insulator or mechanical properties.</p>		
Test date: June. 12, 2022		
2. Mechanical strength of fused parts		
a) Static tension test:		
<p>Apply 125%*60N axial tension to five fuses gradually, without sudden movement.</p> <p>No damage to the fused parts (e.g. broken, loose, dislodged connections, or significantly elongated components) was detected.</p>		
Note: The test passed		

POLIPAR	Test Report	FUSE CUT-OUT
Thermal cycle and torque tests		
		Test date: June.8, 2022
<p>Test Procedure:</p> <p>Each cycle consists of the following:</p> <ul style="list-style-type: none">a. The fuse cutout samples were immersed in water for a minimum of 1h. Water temperature is from 5 to 35 °C. The depth of immersion provides a minium water level of 13mm above any porcelain cavity, filled or open, or any hardware.b. The fuse cutout samples were removed from water. The tempperature of the air surrounding the device is lowered from ambient room temperature to -40°C at a rate controlled to prevent thermal shock. A temperature of -40°C to -50°C was mantained for a minimum of 2h.c. The temperature of the air surrounding the fuse was raised from -40°C to 60°C at a rate controlled to prevent thermal shock. A temperature of 60°C to 70°C was maintained for a minimum of 2h. The device shall be permitted to return to room temperature before reimmersing it in water for subsequent test cycles.		
Test date: June. 10, 2022		
<p>Acceptance of criteria:</p> <p>There shall be no cracks in the insulator or loose hardware after above tests.</p>		
<p>Note: The fuse cutout samples are in good condition after above tests. Test passed.</p>		

POLIPAR	Test Report	FUSE CUT-OUT
Torque tests		
Test date: June.8, 2022		
<p>Test Procedure:</p> <p>Torque tests were performed on fuses that utilize threaded fasteners to attach the hardware to the insulator. Five new fuse cutouts were tested.</p>		
Test date: June.8, 2022		
<p>Acceptance of criteria:</p> <p>A torque of 125% of the nominal values specified by manufacturer POLIPAR should be applied to the threaded fasteners that attach the hardware to the insulators. The specified value by POLIPAR is 20kN, so 25kN torque was tested. The condition of the device after testing must be no damage to the insulators, thread failures, or loose components.</p>		
<p>Note: The fuse cutout samples are in good condition after above tests. The test passed.</p>		

POLIPAR	Test Report				FUSE CUT-OUT		
Radio interference voltage (r.i.v.) tests							
Sample condition	Voltage applied to	Earth connected to	Measurement frequency(MHz)	Test applied voltage(kV)	Measured interference level(dBm)	Radio interference level U(µV)	Maximum allowable interference level(µV)
Fuse in closed position	Aa	F	1	15.3	32.8	43.6	≤250
Fuse in opened position	A	aF	1	15.3	33.3	46.1	≤250
	a	AF	1	15.3	33.5	47.2	≤250

Condition of test object before test: The test sample is working properly.

Note: A——one side terminal of tested parts; a——the other side terminal of tested parts; F——enclosure and base.

The data in the table has been corrected into the standard atmospheric conditions.

Atmospheric conditions of test zone	P= 102.5kPa; Atmospheric correction factor Kt= /	Ambient temperature t= 26°C;	Relative humidity: 65%
		Altitude correction factor Ka= /	

