



Technical Requirements

1. The arc direction of surge arrester release should deviate from other equipments;
2. Materials of high-voltage terminals: Q235
3. Creepage distance 1540mm;
4. Dry arcing distance 660mm.

| | | |
|--------------------------|--|----|
| 51/134 Surge arrester | POLIPAR® THE POWER OF FUTURE | |
| | 01.51.R | 01 |